

# Confirmation

DIPT Group confirms that the VOC content of the architectural and construction sealant with the name:

## Sumogrip Original (White 290ml)

Has been tested for the following specifications.

Sample identification	<b>Sumogrip Original</b>
Product type	Architectural Sealant
Product data	No exempt compounds present No water present Density 1,47 g/ml

The volatile content has been tested gravimetrically by heating to 110°C during 60 minutes.  
The result is:

	Solid content, %mass	Water content, %mass	VOC less water less exempt compounds g/l	VOC limit g/l
<b>Sumogrip Original</b>	99,5	0	8.83 g/L	50

### Conclusion:

Sumogrip conforms to the LEED requirements v4.1 IEQ Credit 4.1 - Low Emitting Materials regarding the VOC content evaluation, as described in SCAQMD Rule 1168 (Amended 2017). The VOC content is below the specified limit value of 50 grams per liter for architectural sealants.

With this confirmation, use of product Sumogrip may qualify for fulfillment of LEED requirements v4.1 IEQ Credit 4.1.

January 30, 2020



Des Duddy  
Director

*Use of US Green Building Council Member logo does not imply that USGBC has approved this confirmation or any mentioned product.*

